



1: Power line Three-color lines connected with U, V and W phases/ yellow and green wires grounded Temperature control line 110°C thermistor two-phase connected with the temperature-control protector 2: Cooling water yielding (2 and 6 ends terminated with 8/6 hoses) 3:Pole change and dust removal pressure 0.2Mpa (6/4 hoses) 4: Air seal pressure 0.1Mpa (6/4 hoses) 5:Tool discharge and air feed pressure 0.70 MPa (6/4 hoses) 6: Cooling influent Pump lift 12m (avoid wrong connection) 7: Quantity of proximity switches Pole hanging and pole discharge NPN (normally open) N.O. Wiring method of the proximity switch Brown wire connected with +24VDC blue wire connected with 0VDC

Signal load end connected with +24VDC/the other end connected with the black wire 8: Handle of the lifting sling Installation and use Model GDL 110-30-24Z-4.5 Voltage 380 V Power 4.5 kw 9.20 A Current 800 Hz Frequency Rotating speed 24000 rpm Pole number 4P Phase number 3 Rotating direction Rotate anticlockwise from the shaft extension end Tool holder BT30 (Parfaite is recommended) Blind rivet BT30-45° (Parfaite is recommended)

23 KG

Weight

thermistor parameter DC power Maximum DC25V/100m supply -20~25℃ ≤300Ω ≤90℃ ≤750₽ 105℃ ≤1650₽ Rated operating temperature 110°C 115°C ≥3990£ ≥125℃ ≥12KΩ Maximum storage ≤160℃ temperature

Special warning:

 The electric main shaft shall be installed at the clamped position; otherwise the bearing will be easily damaged!
The main shaft shall entirely stop before the tool changing. The manual tool changing button shall not act during the rotation of the shaft; otherwise it will easily result in the seizure of the shaft!
The compressed air shall be clean and dry, and the filter accuracy shall be 0.1micron! Air seal is normally open. It is recommended to use the two-level filter, and the filter accuracy is 0.5 micron/ 0.1 micron respectively. The air filter is installed with the self-discharge device.
It is required to set the frequency converter strictly according to the frequency-voltage curve of the electric shaft.

Marks	Number of places	Zoning	Modified document number	Signature	Date						Outline
Designe by	d		Standardized by			Phase mark		Weight	Scale	diagram	
1											
Reviewe by	d										GDL110-30-24Z/4.5
Processe by	:d		Approved by			Total page(s)		Page			

D-30-24Z-4.5